

Official Laboratory Report

Report To: JEFF MYERS

Sample ID: LJ04334

Work Order: 00501341\_01

System Name/Owner:	WMFC	WSSN/Pool ID:	2002156
Collection Address:	4011 WEST ISABELLA RD,SHEPHERD	Source:	TYPE II
Collected By:	JEFF MYERS	Site Code:	
Township/Well#/Section:	GREENDALE/5/15	Collector:	Other
County:	Midland	Date Collected:	05/19/2020 10:15
Sample Point:	KITCHEN SINK	Date Received:	05/19/2020 13:07
Water System:	Untreated Public Distribution System	Purpose:	Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Arsenic	0.003	mg/L	0.002	05/20/2020	0.010	EPA 200.8	7440-38-2

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

Midland County Health Dept.  
220 West Ellsworth  
Midland, MI 48640-5194  
989 832-6679

RL: Reporting Limit	mg/L: milligrams / Liter (ppm)	CFU: Colony Forming Unit
MCL: Maximum Contaminant Level	ng/L: nanograms / Liter (ppt)	CAS: Chemical Abstract Service
AL: Action Level	MPN: Most Probable Number	Laboratory Contact: Marlene Kane
Not Detected: Not detected at or above the reporting limit (RL)		

Official Laboratory Report

Report To: JEFF MYERS

Sample ID: LJ04335

Work Order: 00501341\_02

System Name/Owner:	WMFC	WSSN/Pool ID:	2002156
Collection Address:	40111 W ISABELLA RD,SHEPHERD	Source:	TYPE II
Collected By:	JEFF MYERS	Site Code:	
Township/Well#/Section:	GREENDALE/5/15	Collector:	Other
County:	Midland	Date Collected:	05/19/2020 10:20
Sample Point:	RAW	Date Received:	05/19/2020 13:07
Water System:	Untreated Public Distribution System	Purpose:	Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Arsenic	0.019	mg/L	0.002	05/20/2020	0.010	EPA 200.8	7440-38-2

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

Midland County Health Dept.  
220 West Ellsworth  
Midland, MI 48640-5194  
989 832-6679

RL: Reporting Limit	mg/L: milligrams / Liter (ppm)	CFU: Colony Forming Unit
MCL: Maximum Contaminant Level	ng/L: nanograms / Liter (ppt)	CAS: Chemical Abstract Service
AL: Action Level	MPN: Most Probable Number	Laboratory Contact: Marlene Kane
Not Detected: Not detected at or above the reporting limit (RL)		