

Official Laboratory Report

Report To: BEN LARSON
4011 W ISABELLA RD
SHEPHERD MI 48883

Sample ID: LJ31302
Work Order: 01100095_01

System Name/Owner:	WEST MIDLAND FAMILY CENTER	WSSN/Pool ID:	2002156
Collection Address:	4011 W ISABELLA RD,SHEPHERD	Source:	TYPE II
Collected By:	BEN LARSON	Site Code:	
Township/Well#/Section:	GREENDALE/005/15	Collector:	Other
County:	Midland	Date Collected:	11/02/2020 10:15
Sample Point:	BOILER ROOM SINK	Date Received:	11/02/2020 12:47
Water System:	Untreated Public Distribution System	Purpose:	Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

Per-And Polyfluorinated Alkyl Substances

11CI-PF3OUdS	Not Detected	ng/L	2	11/07/2020		EPA 537.1	763051-92-9c
9CI-PF3ONS	Not Detected	ng/L	2	11/07/2020		EPA 537.1	756426-58-1d
ADONA	Not Detected	ng/L	2	11/07/2020		EPA 537.1	919005-14-4e
HFPO-DA	Not Detected	ng/L	2	11/07/2020	370	EPA 537.1	13252-13-6b
NEtFOSAA	Not Detected	ng/L	2	11/07/2020		EPA 537.1	2991-50-6
NMeFOSAA	Not Detected	ng/L	2	11/07/2020		EPA 537.1	2355-31-9
PFBS	Not Detected	ng/L	2	11/07/2020	420	EPA 537.1	375-73-5
PFDA	Not Detected	ng/L	2	11/07/2020		EPA 537.1	335-76-2
PFDoA	Not Detected	ng/L	2	11/07/2020		EPA 537.1	307-55-1
PFHpA	Not Detected	ng/L	2	11/07/2020		EPA 537.1	375-85-9
PFHxA	Not Detected	ng/L	2	11/07/2020	400000	EPA 537.1	307-24-4
PFHxS	Not Detected	ng/L	2	11/07/2020	51	EPA 537.1	355-46-4
PFNA	Not Detected	ng/L	2	11/07/2020	6	EPA 537.1	375-95-1
PFOA	Not Detected	ng/L	2	11/07/2020	8	EPA 537.1	335-67-1
PFOS	Not Detected	ng/L	2	11/07/2020	16	EPA 537.1	1763-23-1
PFTA	Not Detected	ng/L	2	11/07/2020		EPA 537.1	376-06-7
PFTrDA	Not Detected	ng/L	2	11/07/2020		EPA 537.1	72629-94-8
PFUnA	Not Detected	ng/L	2	11/07/2020		EPA 537.1	2058-94-8

RL: Reporting Limit	mg/L: milligrams / Liter (ppm)	CFU: Colony Forming Unit
MCL: Maximum Contaminant Level	ng/L: nanograms / Liter (ppt)	CAS: Chemical Abstract Service
AL: Action Level	MPN: Most Probable Number	Laboratory Contact: Marlene Kane
Not Detected: Not detected at or above the reporting limit (RL)		

Sample ID: LJ31302

Work Order: 01100095_01

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

**Midland County Health Dept.
220 West Ellsworth
Midland, MI 48640-5194
989 832-6679**

RL: Reporting Limit

MCL: Maximum Contaminant Level

AL: Action Level

Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)

ng/L: nanograms / Liter (ppt)

MPN: Most Probable Number

CFU: Colony Forming Unit

CAS: Chemical Abstract Service

Laboratory Contact: Marlene Kane