

**MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
DRINKING WATER LABORATORY**

USEPA Region V Drinking Water Cert. No. MI00003
P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562



**Sample Number
LI15009**

Official Laboratory Report

Report To: JEFF MYERS

System Name/Owner:	WEST MIDLAND FAMILY CENTER	WSSN/Pool ID:	2002156
Collection Address:	4011 W ISABELLA RD,SHEPHERD	Source:	TYPE II
Collected By:	JEFF MYERS	Site Code:	
Township/Well#/Section:	GREENDALE/5/15	Collector:	Public Water Supply Operator
County:	Midland	Date Collected:	11/09/2018 09:45
Sample Point:	SOFTNER DISCHARGE	Date Received:	11/09/2018 12:01
Water System:	Untreated Public Distribution System	Purpose:	Other

TESTING INFORMATION			REGULATORY INFORMATION			
Analyte Name	Result (mg/L)	Date Tested	RL (mg/L)	MCL/AL (mg/L)	Method	CAS #
Arsenic	0.007	11/14/2018	0.002	0.010	EPA 200.8	7440-38-2

The analyses performed by the MDEQ Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below:

**Midland County Health Dept.
220 West Ellsworth
Midland, MI 48640-5194
989 832-6679**

CAS# : Chemical Abstract Service Registry Number
MCL : Maximum Contaminant Level
AL : Action Level
RL : Reporting Limit

mg/L : milligrams / Liter (ppm)
ppm : parts per million
MPN : Most Probable Number
CFU : Colony Forming Unit

Laboratory Contact: Scott Hayward