

Official Laboratory Report

Report To:

**Sample ID: LK02587**  
**Work Order: 20300563\_01**

System Name/Owner:	WEST MIDLAND FAMILY CENTER	WSSN/Pool ID:	52002156
Collection Address:	4011 W ISABELLA, SHEPHERD	Source:	TYPE II
Collected By:	ALAN BLOCH RS	Site Code:	
Township/Well#/Section:	GREENDALE/005/	Collector:	Other
County:	Midland	Date Collected:	03/02/2022 11:45
Sample Point:	KITCHEN SINK	Date Received:	03/03/2022 11:14
Water System:	Other	Purpose:	Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Coliform Organisms per 100 mL	Not Detected			03/03/2022		SM 9223 B	TC-00-B

Explanation of Coliform Results:

Not Detected = Coliform and E. coli bacteria were not found  
 Positive = Total Coliform was found and E. coli bacteria was not found  
 EC Positive = Coliform and E. Coli bacteria were found

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

Midland County Health Dept.  
220 West Ellsworth  
Midland, MI 48640-5194  
989 832-6679

RL: Reporting Limit	mg/L: milligrams / Liter (ppm)	CFU: Colony Forming Unit
MCL: Maximum Contaminant Level	ng/L: nanograms / Liter (ppt)	CAS: Chemical Abstract Service
AL: Action Level	MPN: Most Probable Number	Laboratory Contact: Marlene Kane
Not Detected: Not detected at or above the reporting limit (RL)		